



208 NW 1st Avenue, Faribault, MN 55021
507-334-2222 and 507-334-0508 (fax)



FIREWORKS SALES COMPLIANCE INSPECTION CHECKLIST

After you have applied for and have been granted a license to sell fireworks in the City of Faribault, the Faribault Fire Department will inspect the location and premises where your fireworks will be sold. **You may not sell any product until the inspection has been completed and approved by the Fire Department.** *Please call 507-334-2222 to schedule the inspection when your tent/display is set up!

Please note that you must be in compliance with the following items:

- Your City of Faribault License must be publicly displayed.
- Your Transient license from Rice County must be displayed. (Required for tents only)
- Your retail facility is limited to one story.
- Your facility must have at least two exits.
- There must be "No Smoking" signs clearly posted.
- There must be a sign stating no one is allowed to smoke within 50 feet of the fireworks stand.
- You must have signs stating customers "must be 18 years old to purchase fireworks".
- Fire extinguishers must be located within 75 feet of display
 - **1(one) – water and 1 (one) – 2A-10BC minimum**
- The sales area must be at least 50 feet from any fuel dispensing apparatus.
- The sales area must be at least 300 feet from any bulk flammable/combustible liquid or gas storage area.
- The facility may not have exterior fireworks storage, displays or sales area.
- Fireworks display heights are limited to six (6) feet or less.
- The sales and storage areas must be clear of debris and any loose pyrotechnic compounds.
- Vacuums or mechanical devices are not allowed for removal.
- All fireworks must be "packaged" and all fuses are covered.
- Fireworks shall be under supervision at all times when open for business.
- The continuous display cannot exceed 16 feet without there being a flame break in place.
- The flame break must be the full depth of the display.
- The flame break must extend to no less than 6" above the top of the display.
- The Fire Department Inspection must be completed and approved prior to any product being sold.

Thank you!

Gina Carlson, Fire Department Secretary